



Certificate of Compliance

Certificate: 2488195

Master Contract: 253639

Project: 2488195

Date Issued: September 20, 2012

Issued to: CDI

1801 N Juniper Ave
Broken Arrow, OK 74012
USA
Attention: Eric Farque

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



James Lim

Issued by: James Lim

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Division 1, Groups C and D; T6, Tamb -50°C to +80°C

Model: CD52 PIG PASSAGE DETECTOR

24Vdc; 28mA; 0.67W or 1.5Vdc; 1.8mA; 0.0027W - Battery

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No.0-10 - General Requirements-Canadian Electrical Code, Part II

CSA Standard C22.2 No.0.4-04 - Bonding of Electrical Equipment (Protective Grounding)

CSA Standard C22.2 No.94-M1991 - Special Purpose Enclosures

CSA Standard C22.2 No.142-M1987 - Process Control Equipment

CSA Standard C22.2 No.30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations



Certificate: 2488195

Master Contract: 253639

Project: 2488195

Date Issued: September 20, 2012

ANSI/UL Standard 50 Edition 11 - Enclosures for Electrical Equipment

UL 508, Edition 17 - Industrial Control Equipment

UL 1203, Edition 4 - Explosion-Proof and Dust Ignition Proof Electrical Equipment for Use in Hazardous (Classified) Locations